



## CERTIFICATE OF COMPLIANCE

**Date:** March 22nd 2021

**Code or Series:** MAS51/55 600V Series Instrumentation Cables

**Product Name / Description:** Multipair foil screened instrumentation cables  
90°C , Overall foil screen (CS) , 600V Rated Insulation.

These products have been manufactured to meet the following standards:

**Standards:** **AS/NZS1125, AS/NZS3808, AS/NZS60079.14,  
IEC60332-1-2, IEC 60332-3-22, RoHS Compliant.**

**All Fillers used are Non-hydroscopic Polypropylene**

Product Manager - Maser

Geoff Tennent



**Disclaimer:** Although Maser Communications NZ Limited makes every reasonable effort to ensure their accuracy at the time of this publication, information and specifications described herein are subject to error or omission and to change without notice. Maser provides the information and specifications herein on an "AS IS" basis, with no representations or warranties, whether express, statutory or implied. In no event will Maser be liable for any damages (including consequential, indirect, incidental, special, punitive, or exemplary damages) whatsoever, even if Maser has been advised of the possibility of such damages, whether in an action under contract, negligence or any other theory, arising out of or in connection with the use, or inability to use, the information or specifications described herein.