



## CERTIFICATE OF COMPLIANCE

**Date:** August 30th 2018

**Code or Series:** MAS5xxx Series Instrumentation Cables

**Product Name / Description:** Multipair & Triad foil screened instrumentation cables 110VAC 90°C , Overall foil screen (CS), Overall and individual foil screen (ESCS) and Steel wire armour.

These products have been manufactured to meet the following standards:

**Standards:** AS/NZS1125, AS/NZS3808, AS/NZS60079.14,  
IEC60332-1-2, IEC 60332-3-22, RoHS Compliant.

Product Manager - Maser

Geoff Tennent



**Disclaimer:** Although Maser Communications NZ Limited makes every reasonable effort to ensure their accuracy at the time of this publication, information and specifications described herein are subject to error or omission and to change without notice. Maser provides the information and specifications herein on an "AS IS" basis, with no representations or warranties, whether express, statutory or implied. In no event will Maser be liable for any damages (including consequential, indirect, incidental, special, punitive, or exemplary damages) whatsoever, even if Maser has been advised of the possibility of such damages, whether in an action under contract, negligence or any other theory, arising out of or in connection with the use, or inability to use, the information or specifications described herein.